City of Fremont Fire Final Checklist Guide

This checklist is to be used as a guide to confirm which fire and life safety issues are appropriate to a particular project within the City of Fremont. This checklist may not represent all conditions exclusive to every project. This list is to aide in figuring out the fire expectations for any given project. <a href="mailto:Emailto

Address	Permit	Applicable	Completed
Rated Construction			
Exit Signs/Emergency Lighting functioning in both emergency & normal mode			
General Exiting			
Fire Smoke Dampers require	es monitoring		
Posted Address 8" numbers on	r larger for commercial also contrasting color		
Fire Extinguishers 2-A:10-B	:C or larger, K type for Commercial Kitchens		
HVAC Smoke Detectors (S	SPR) requires monitoring		
High Piled/Rack Combusti	ible Storage		
Annual Fire Code Assembly Permit occupant load greater than 49			
Automatic Fire Sprinkler System (AFES, SPR)			
5 Year Certification for Al	FES current within the last 5 years		
Underground Fire Line/Ki	nox Caps (SPR) includes address signs		
Fire Department Access/R			
Fixed Fire Protection System (SPR) Dry Chem, Liquid Systems, CO2, Clean Agents These systems also require monitoring			
Fire Alarm System (SPR)	requires rough installation inspection and monitoring		
Fire Sprinkler Monitoring System (SPR) requires rough installation inspection Also requires approved pre-test printout prior to scheduling test inspection			
Fire Alarm System Certificate Request posted, current & correct			
Medical Gas Systems			
Knox Box (call Fire Prevention 510-494-4280) gates may have Knox locks			
Other			

Inspector's Name & Phone: